

EARL THOMAS RESERVOIR

ROOF EXPANSION

W 943-A

1943

1943

① NOTE
 SET PK NAIL
 IN E OF AC ROAD
 TO FILTER PLANT

CHECK ROOF EXPANSION
 EARL THOMAS RES

2+3 on Q

9+10 .025 →

15+16 .015 →

20+21 .015 →

22 .085 →

24+25 .015 →

27 .115 →

Wall

Piping

5/4

Line

Ref

.05 →
 → .997 ←

.055 →
 → .990 ←

.040 →
 → .960 ←

.015 →
 → .960 ← 28+29

Ref Line "M"

Cone Temp 89°F
 in Shade

1 PM Oct 29, 62
 West
 Williams
 Allen
 Tamandary

→ ← .048 Q 19

→ ← .052 Q 21

→ ← .020 Q 24

.015 → ← Q 26

USED TO SET
 NEW BASE LINE
 CONTROL

Plotted
 M

• Set PK Nail in Q
 of AC Road

• Pipe has been planned
 out

Check Roof Expansion
 EARL THOMAS Res

• used
 PK Nail

9+10 .022 → ←

15+16 .020 → ←
 Cap Pipe

20+21 .015 → ←
 Line

22 .015 → ←
 Ref

24+25 .009 → ←

27 .098 → ←

.053 → ←
 → .995 ←

.066 → ←
 → 1.000 ←

CORRECTED 9-22-63
 +.07N.
 PK

.050 → ←
 → .970 ←

.020 → ←
 → .960 ←

15+16

28+29

set PK Nail
 in line with
 Ely Edge Res
 in AR Room
 9.68'
 set on 3/4" IP

West
 Williams
 Allen
 Tamardana

Cone Temp 2 PM Aug 9, 63
 104°F in Shade

Well
 .070 → ← Q 19

Repairing
 .073 → ← Q 21

Wly
 .037 → ← Q 21

Line
 .030 → ← Q 26

Ref


Check Roof Expansion
Earl Thomas Res

West
Williams
Schulzmacher
(2486)

Cond Temp
89°F
in Shade

10:00 AM
Oct 2, 64

Used PK Nail



.048 → ← # 19

.051 → ← # 21
Wall
Capillary

.020 → ← # 24
Line
Line

.012 → ← # 26
Ref
Ref Line

PK Nail in Road

57.19

Set Capped T Bar Fence 23 Fence

Plotted PK

CHECK ROOF EXPANSION
EARL THOMAS RES

used px
Nail

West
Williams
Schuhmscher
Casey

0000 Temp 3 P11
= 70.2 Feb 2, 66

9+10 0.060" → ←

15+16 0.055" → ←
Wall
Coping

20+21 0.015" → ←
Shy

22 0.051" → ←
Line

24+25 0.010" → ←
Ref

27 0.095" → ←

→ ← 0.040"
← → 0.985"

→ ← 0.053"
← → 0.991"

→ ← 0.028"
← → 0.959"

→ ← .007"
← → 0.958"

(28+29)
M

→ ← 0.038" ∅ 19

Wall

→ ← 0.046" ∅ 21

Coping

→ ← 0.009" ∅ 24

Line

→ ← 0.006" ∅ 26

Ref



Plotted P.J.

CHECK ROOF EXPANSION
EARL THOMAS RES

West
Williams
Schuhmacher
Seelye

Cone Temp
80°F

2:30 PM
April 3, 67







Plotted
JF

CHECK ROOF EXPANSION
EARL THOMAS RES

WEST
WILLIAMS
KELLY

00NO TEMP
78°F

3 PM
NOV 19, 68



Ref

Plotted
1/2

